

Adurel International
 820 Water St
 Racine, WI 53403

Report Date: 8/10/07
 Revision #1

- Analytical Results -

Lab #:07A6052-001 **Sample ID:**MS2200/MS2100


The material identified above was tested by preparing a water extract in accordance with NSF Protocol 151, "Health Effects from Rainwater Catchment System Components", specifically as it applies to rainwater catchment systems used in roofing. The extract was then analyzed for the metals listed below using methods acceptable to the US EPA. This list includes all the metals found in the Primary Drinking Water standards.

Test	Result	Units	LOD	MCL	Analysis Date	By	Method	Flag
Antimony	<0.001	mg/L	0.001	0.006	8/9/07	GGG	7041	1
Arsenic	<0.001	mg/L	0.001	0.010	8/9/07	GGG	7060A	1
Barium	<0.001	mg/L	0.001	2.0	8/9/07	GGG	6010C	1
Beryllium	<0.0005	mg/L	0.000	0.004	8/9/07	GGG	6010C	1
Cadmium	<0.002	mg/L	0.002	0.005	8/9/07	GGG	6010C	1
Copper	<0.005	mg/L	0.005	1.3	8/9/07	GGG	6010C	1
Mercury	<0.0001	mg/L	0.000	0.002	8/9/07	GGG	245.7	1
Lead	<0.001	mg/L	0.001	0.015	8/9/07	GGG	7421	1
Chromium	<0.005	mg/L	0.005	0.10	8/9/07	GGG	6010C	1
Selenium	<0.002	mg/L	0.002	0.05	8/9/07	GGG	7740	1
Thallium	<0.0005	mg/L	0.0005	0.0005	8/9/07	GGG	7841	1

LOD = Limit of Detection

MCL = Maximum Concentration Limit (highest concentration allowed by Primary Drinking Water Standards).

FLAG	Comment
1	All laboratory QC requirements were met for this sample.



Gary G. Geipel
 Senior Analyst

6125 West National Avenue, P.O. Box 14513, Milwaukee, WI 53214
 (414) 475-6700 FAX: (414) 475-7216 www.sflabs.com
 Toll-Free: 800-300-6700